

## EasySolar-II 48/5000/70-50 MPPT 250/100GX MPPT remote wire wrongly connected

### Problem description

On the new EasySolar-II 48/5000 there is a mis wiring of the MPPT's remote ON/Off, the little red wire is connected to the port L instead of H causing the MPPT to not charge.

### Product PN:

PMP482507010 - EasySolar-II 48/5000/70-50 MPPT 250/100 GX

### Serial number batches

- HQ2105
- HQ2125

### Solution

Remove the front panel to have access to the MPPT.

Disconnect the thin red wire from the Remote connector port 'L' (right side) and connect to connector port 'H' (left side).



The photo above shows a wrong connection of the thin red wire to the port L instead of H



The red wire must be connected to the port 'H'.



Front panel must be removed to have access to the MPPT