

Firmware update for SZ_Q8ESS_GJAutomotive

You can use this page to update the firmware of devices connected to your GX device. For detailed instructions about the update process visit: [Remote Firmware Update Manual](#).

Rescan

Device description	Product Id	Id	Installed	Latest	Updatable	
SmartSolar MPPT RS 450/100	A110	/dev/ttyO0	v1.05	v1.11	Update Device	⋮
Color Control GX	C001		v3.10~2	v3.10~2	✓ Up to date	
Quattro 48/8000/110-2x100 rev2	2655	/dev/ttyO1	v502	v502	✓ Up to date	⋮

The screenshot displays the Remote Console interface for the device 'SmartSolar MPPT RS 450/100'. The top header shows the device name, product ID 'A110', ID '/dev/ttyO0', installed version 'v1.05', latest version 'v1.11', and an 'Update Device' button. The main content area shows the 'Generator start/stop settings' menu, which includes a 'Conditions' section with a right arrow, and several settings: 'Minimum run time' set to '2m', 'Detect generator at AC input' (toggle off), 'Alarm when generator is not in auto start mode' (toggle off), and 'Quiet hours' (toggle off). Below these is a 'Run time and service' section with a right arrow. At the bottom of the settings panel are 'Pages' and 'Menu' icons. On the right side, a blue navigation overlay is visible, featuring an 'esc' button, a back arrow, a central directional pad, and the text 'SZ_Q8ESS_GJAutomotive Remote Console'.