

### Measurement Result for Batteries SOC Problem ( 1\_3\_2023 )

Group	No	SOC 99%	Status	SOC 81%	Status
<b>A</b>	1	99%		15%	
	2	51%	Cell Voltage OV when Charging	_	Unreachable ( Communication Error )
	3	99%		97%	
	4	98%		95%	
	5	99%		95%	
<b>B</b>	1	99%		_	Sys Error ( Internal Communication ) / Red Alarm Led is ON
	2	70%	Cell Voltage OV	_	Unreachable ( Communication Error )
	3	99%		95%	
	4	99%		95%	
	5	99%		95%	
<b>C</b>	1	99%		95%	
	2	99%		95%	
	3	98%		96%	
	4	99%		95%	
	5	98%		97%	
<b>D</b>	1	99%		98%	
	2	99%		96%	
	3	99%		94%	
	4	99%		95%	
	5	99%		96%	
<b>E</b>	1	51%		5%	Sys Error ( Internal Communication ) / Red Alarm Led is ON
	2	94%		_	Unreachable ( Communication Error ) / Red Alarm Led is ON
	3	99%		96%	
	4	99%		95%	
	5	99%		95%	