

**ESS** 10:19

- Minimum SOC (unless grid fails) 55%
- Peak shaving Always
- Limit inverter power
- Grid setpoint 20W
- Grid feed-in >
- Scheduled charge levels Inactive >

Pages Menu

esc

Osman  
Remote Console

**Grid feed-in** 10:20


- AC-coupled PV - feed in excess
- DC-coupled PV - feed in excess
- Feed-in limiting active No

Pages Menu

esc

Osman  
Remote Console

ESS		10:20
Mode	Optimized (without BatteryLife)	
Grid metering	External meter	
Inverter AC output in use	<input checked="" type="checkbox"/>	
Multiphase regulation	Individual phase	
Minimum SOC (unless grid fails)	55%	
Peak shaving	Always	
Pages		Menu



Osman  
Remote Console

DVCC		10:21
<b>CAUTION: Read the manual before adjusting</b>		
DVCC	Forced on <input checked="" type="checkbox"/>	
Limit charge current	<input checked="" type="checkbox"/>	
Maximum charge current	200A	
Limit managed battery charge voltage	<input type="checkbox"/>	
SVS - Shared voltage sense	Forced off	
Pages		Menu



Osman  
Remote Console

DVCC		10:21
SVS - Shared voltage sense	Forced off	
STS - Shared temperature sense	Forced off	
SCS - Shared current sense	<input checked="" type="checkbox"/>	
SCS status	Disabled (External control)	
Controlling BMS	Automatic selection	
Auto selected: Pylontech battery		
Pages		Menu



Osman  
Remote Console

GX Firmware

**Firmware** 10:22

Firmware version	v3.01
Build date/time	20230717162050
Online updates	>
Install firmware from SD/USB	>
Stored backup firmware	>

**Pages** **Menu**

esc ↩



Osman  
Remote Console